

Please note: This drawing shows a typical configuration of equipment and does not necessarily show the equipment currently installed in the unit. Verify the specific equipment currently in the unit with a KTG representative.








THE DESIGN AND DETAILS DISCLOSED HEREIN ARE THE EXCLUSIVE PROPERTY OF CARLIN MANUFACTURING L.L.C. AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF CARLIN MANUFACTURING L.L.C. © 2005 CARLIN MANUFACTURING L.L.C.

REVISION			
DATE	REV	DESCRIPTION	APPROVED

FROM MODULE 1 CC553"
STUB OUT LOCATION
SEE DRAWING#
554P04-0-02 AND
554P04-0-03

WATER HEATER
175,000 BTU

HVAC "B"
67,500 BTU

SYMBOL	DESCRIPTION
	VALVE, GAS
	TEE
	90° ELBOW
	REGULATOR
	FLEX TUBING ASSEMBLY
	SOLENOID VALVE
	HYDRASTATIC RELIEF

- NOTES:
1. GAS LINES SHALL BE IN BLACK STEEL PIPE, SCHEDULE 40, UNLESS OTHERWISE SPECIFIED.
 2. GAS LINES SHALL BE ADEQUATELY SUPPORTED WITH GALV. STL. 2 HOLE STRAPS AT 3' O.C. MAX.

Kitchens To Go

KTG-554
MODULAR KITCHEN UNIT

DATE: 08-24-05	BY: GSF
DATE: 08-24-05	BY: GSF
DATE: 08-24-05	BY: GSF
DATE: 08-24-05	BY: GSF

SCALE: 1:1

CARLIN
LP GAS
PLUMBING SCHEMATIC

DATE: 08-24-05	BY: GSF
DATE: 08-24-05	BY: GSF
DATE: 08-24-05	BY: GSF
DATE: 08-24-05	BY: GSF

SCALE: 1:1