


Please note: This drawing shows a typical configuration of equipment and does not necessarily show the equipment currently installed in the unit. Verify the specific equipment currently in the unit with a KTG representative.

THE DESIGN AND DETAILS DISCLOSED HEREIN ARE THE EXCLUSIVE PROPERTY OF CARLIN MANUFACTURING LLC. AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF CARLIN MANUFACTURING LLC.  
©2005 CARLIN MANUFACTURING LLC.

REVISIONS				
NO.	REV.	DESCRIPTION	DATE	APPROVED

NOTES:

1. GAS LINES SHALL BE IN BLACK STEEL PIPE, SCHEDULE 40, UNLESS OTHERWISE SPECIFIED.
2. GAS LINES SHALL BE SUPPORTED WITH PIPE STRAPS TO WITHSTAND ON AND OFF-ROAD CONDITIONS.
3. SOLENOID VALVE TO BE CONNECTED TO EMERGENCY SHUT OFF VALVE AND FIRE SUPPRESSION SYSTEM.



SYMBOL	DESCRIPTION
	VALVE, GAS
	TEE
	90° ELBOW
	REGULATOR
	FLEX TUBING ASSEMBLY
	REDUCER, 1 1/2" x 3/4"
	SOLENOID VALVE

**Kitchens To Go**  
WISCONSIN VETERAN'S HOME KITCHEN UNIT

SIZE: B	CAGE CODE:	ENG. NO.: 560P04-0-01	REV.:
SCALE: 1:8	DWG. NO.:	REV. NO.:	SHEET:

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TO LEAST FRACTIONAL PART  
FRACTIONS: 1/8 INCHES  
FRACTIONS: 1/16 INCHES  
FRACTIONS: 1/32 INCHES  
FRACTIONS: 1/64 INCHES  
FRACTIONS: 1/128 INCHES  
FRACTIONS: 1/256 INCHES

BOUNDARY SCALE DRAWINGS  
DIMENSIONS PREPARED IN ACCORDANCE WITH ALL CITY, COUNTY, STATE AND FEDERAL REQUIREMENTS

UNIT NO. CM-560	<b>CARLIN MANUFACTURING LLC</b>		
APPROVALS	DATE	LP GAS PLUMBING SCHEMATIC	
DRAWN: GSF	05-13-05	SIZE: B	CAGE CODE: 560P04-0-01
CHECKED:		SCALE: 1:8	REV.:
ENCH:			
DESIGN ACTIVITY:			
REV.:			

8 7 6 5 4 3 2 1