Please note: This drawing shows a typical configuration of equipment and does not necessarily show the equipment currently installed in the unit. Verify the specific equipment currently in the unit with a KTG representative.

THE DESIGN AND DETAILS DISCLOSED HEREIN ARE THE EXCLUSIVE PROPERTY OF CARLIN MANUFACTURING L.L.C. AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF CARLIN MANUFACTURING L.L.C. © 2005 CARLIN MANUFACTURING L.L.C.

REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED

KTG-562

200AMP 120/220VOLTS 3 WIRE 60HZ 1PH

						PHASE											
AWG	COLOR	ITEM	P	AMPS	CIRC.	A		B		C		P	AMPS	CIRC.	ITEM	AWG	COLOR
6	B	HVAC	2	70	1	5403	800					1	15	2	LIGHTS	14	B
6	R	HVAC	2	70	3			5403	800			1	15	4	RECEPS C/S	14	R
14	B	WATER HEATER	1	15	5	800	800					1	15	6	RECEPS R/S	14	B
14	R	RECEPS	1	15	7			800						8	SPACE		
		RECEPS			9	800	800					1	15	10	RECEPS	14	B
		SPACE			11				800			1	15	12	RECEPS	14	R
		SPACE			13									14	SPACE		
		SPACE			15									16	SPACE		
		SPACE			17									18	SPACE		
		SPACE			19									20	SPACE		
						7003	2400	6203	1600								
						9403		7803									

TOTAL= 17206 WATTS

I = 74.81 AMPS

Kitchens To Go

KTG-562
MODULAR PREP UNIT

SIZE	CAGE CODE	DWG. NO.	REV.
B		562E01-0-01	

SCALE 1:1 WEIGHT SHEET

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TOLERANCES ARE:
FRACTIONS ± DECIMALS .XX= ± .03 .XXX= ± .010
ANG ± 0°

DO NOT SCALE DRAWINGS

DRAWINGS PREPARED IN ACCORDANCE WITH MIL-T-8100, MIL-STD-100, AND ANSI Y14.5

SIMILAR TO

PART NO.	KTG-562	
	APPROVALS	DATE
DRAWN	GSF	08-24-05
CHECKED		
ENGR.		
DESIGN ACTIVITY		
REV.		

CARLIN MANUFACTURING, L.L.C.

AC ELECTRICAL
PANEL SCHEDULE

SIZE	CAGE CODE	DWG. NO.	REV.
B		562E01-0-01	

SCALE 1:1 WEIGHT SHEET