

Please Note: This drawing shows a typical configuration of equipment and does not necessarily show the equipment currently installed in the unit. Verify the specific equipment currently in the unit with a KTG representative.

THE DESIGN AND DETAILS DISCLOSED HEREIN ARE THE EXCLUSIVE PROPERTY OF CARLIN MANUFACTURING LLC. AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF CARLIN MANUFACTURING LLC. © 2005 CARLIN MANUFACTURING LLC.

REVISIONS				
DATE	REV	DESCRIPTION	DATE	APPROVED
	A	ADDED MORE CIRCUITS	05-05-06	

575 AVENTURA HOSPITAL															
120/208VOLTS 4 WIRE 60HZ 3PH															
200 AMP															
PHASE															
AWG	COLOR	ITEM	QTY	AMPS	WATTS	A	B	C	P	AMPS	WATTS	ITEM	AWG		
14	B	HVAC	3	50	1	3602	800			1	15	2	LIGHT	14	
14	R	HVAC	3	50	3		3602	800		1	15	4	RECEPS/CS	14	
14	BL	HVAC	3	50	5			3602	800	1	15	6	RECEPS/RS	14	
14	B	WALKIN FREEZER	2	20	7	1718	800			1	15	8	RECEPS	14	
14	R	WALKIN FREEZER	2	20	9		2064	800		1	15	10	RECEPS	14	
12	BL	WALKIN COOLER	2	20	11				1484	1200	1	20	12	RECEPS	12
12	B	WALKIN COOLER	2	20	13	1464	1200			1	20	14	RECEPS	12	
12	R	WALKIN COOLER	2	20	15			1464	1200	1	20	16	RECEPS	12	
12	BL	WALKIN COOLER	2	20	17				1464	1200	1	20	18	RECEPS	12
12	B	WALKIN COOLER	2	20	19	1464						20	SPACE		
12	R	WALKIN COOLER	2	20	21		1464					22	SPACE		
		SPACE			23							24	SPACE		
		SPACE			25							26	SPACE		
			5246	2800	5594	2800	6530	3200							
			11046		11394		9730								
TOTAL= 32170 WATTS															
I = 83.29761 AMPS															

Kitchens To Go
KTG MODULAR KITCHEN COMPLEX
 DRAWING NO. 575E01-0-01
 DATE 01-01-06
 SCALE 1:1

CARLIN MANUFACTURING LLC
575
AC PANEL SCHEDULE
 APPROVALS: RR DATE: 01-01-06
 DRAWN BY: B
 SCALE: 1:1