

**Please Note:** This drawing shows a typical configuration of equipment and does not necessarily show the equipment currently installed in the unit. Verify the specific equipment currently in the unit with a KTG representative.

THE DESIGN AND DETAILS DISCLOSED HEREIN ARE THE EXCLUSIVE PROPERTY OF CARLIN MANUFACTURING LLC. AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF CARLIN MANUFACTURING LLC. © 2006 CARLIN MANUFACTURING LLC.

REV		DESCRIPTION	DATE	APPROVED
A		ADDED MORE CIRCUITS	05-06-06	

AVG		COLOR		ITEM	P	AMPS	CIRC.	PHASE			P	AMPS	CIRC.	ITEM	AVG	COLOR
8 B		14 B						A	B	C						
				HVAC	3	50	1	3602	800					LIGHT		
				HVAC	3	50	3		3602	800		1	15	4	RECEPS/CS	14 R
				HVAC	3	50	5			3602	800	1	15	6	RECEPS/RS	14 BL
				COFFEE URN	3	50	7	5000	800			1	15	8	RECEPS	14 B
				COFFEE URN	3	50	9		5000	800		1	15	10	RECEPS	14 R
				COFFEE URN	3	50	11			5000	1200	1	20	12	RECEPS	12 BL
				SPACE			13	1200				1	20	14	RECEPS	12 B
				SPACE			15		1200			1	20	16	RECEPS	12 R
				SPACE			17						18	SPACE		
				SPACE			19						20	SPACE		
								8602	2800	8602	2800	8602	2000			
								11402		11402		10602				
								TOTAL=	33406	WATTS						
								I =	92.7285	AMPS						

**Kitchens To Go**  
 KTG  
 MODULAR KITCHEN COMPLEX

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TO NEAREST 1/8".  
 FINISHES: SEE WALLS  
 FINISH: SEE WALLS  
 FINISH: SEE WALLS  
 FINISH: SEE WALLS

DATE NO. 576E01-0-01  
 SHEET 1.1

UNIT NO. 576

APPROVALS: RR DATE: 02-02-06

**CARLIN**  
 AC PANEL SCHEDULE

DATE: 05-06-06  
 SHEET 1.1