


Please Note: This drawing shows a typical configuration of equipment and does not necessarily show the equipment currently installed in the unit. Verify the specific equipment currently in the unit with a KTG representative.

THE DESIGN AND DETAILS DISCLOSED HEREIN ARE THE EXCLUSIVE PROPERTY OF CARLIN MANUFACTURING LLC. AND SHALL NOT BE COPIED OR REPRODUCED IN WHOLE OR IN PART WITHOUT THE PRIOR WRITTEN CONSENT OF CARLIN MANUFACTURING LLC. © 2009 CARLIN MANUFACTURING LLC.

REVISIONS			
ZONE	REV	DESCRIPTION	DATE
	A	CHANGED BTUS	05-05-06

NOTES:

1. GAS LINES SHALL BE IN BLACK STEEL PIPE, SCHEDULE 40, UNLESS OTHERWISE SPECIFIED.
2. GAS LINES SHALL BE SUPPORTED WITH PIPE STRAPS TO WITHSTAND ON AND OFF-ROAD CONDITIONS.
3. SOLENOID VALVE TO BE CONNECTED TO EMERGENCY SHUT OFF VALVE AND FIRE SUPPRESSION SYSTEM.



FRONT OF UNIT

SYMBOL	DESCRIPTION
	VALVE, GAS
	TEE
	90° ELBOW
	REGULATOR
	FLEX TUBING ASSEMBLY
	SOLENOID VALVE
	HYDRASTATIC RELIEF

Kitchens To Go
 KTG
 MODULAR KITCHEN COMPLEX

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES TO FRACTIONS ARE:
 FRACTIONS DECIMALS
 1/8" 1/8" 3/16" 1/4" 1/2" 3/4" 1" 1 1/4" 1 1/2" 1 3/4" 2" 2 1/4" 2 1/2" 3" 3 1/4" 3 1/2" 4" 4 1/4" 4 1/2" 5" 5 1/4" 5 1/2" 6" 6 1/4" 6 1/2" 7" 7 1/4" 7 1/2" 8" 8 1/4" 8 1/2" 9" 9 1/4" 9 1/2" 10" 10 1/4" 10 1/2" 11" 11 1/4" 11 1/2" 12" 12 1/4" 12 1/2" 13" 13 1/4" 13 1/2" 14" 14 1/4" 14 1/2" 15" 15 1/4" 15 1/2" 16" 16 1/4" 16 1/2" 17" 17 1/4" 17 1/2" 18" 18 1/4" 18 1/2" 19" 19 1/4" 19 1/2" 20"

DO NOT SCALE DRAWINGS

DESIGNER PREPARED IN ACCORDANCE WITH M.I. 1-9106, M.I. 870-101 AND AMB 1743

SCALE: 1:4

UNIT NO. 576

APPROVALS: RR DATE: 02-02-06

CHICAGO

ENGINEER

DESIGN ACTIVITY

REV.

CARLIN
 LP GAS
 PLUMBING SCHEMATIC

SCALE: 1:4

DATE: 05-05-06

REV: B

SCALE: 1:4